



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. No detailed internal inspection of flues (Integrity, Constructions and Lining) has been carried out.

Certificate Reference

49 Bute Ave 1

Certificate No: 1001229

Engineers Details

Trading Title

W Bridge Ltd

Address

25 Condon Road
Barrow Upon Soar
Leicestershire

Post Code: LE12 8NQ

Installation Details

Installation Address

49 Bute Ave
Lenton
Nottingham

Post Code: NG7 1QB

Client Details

Client Address

Parr Houses
90 Paget Street
Loughborough
Leics

Post Code: LE11 5DT

Gas Safe No:

215675

Telephone No:

07776150889

Telephone No:

Telephone No:

Telephone No:

Telephone No:

Appliance Details

Location	Appliance Type	Make	Model	CO2 Reading	CO Reading	FlueType (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
Kitchen	Combi boiler	Main	Main combi 30HE	8.6	62	RS	N/A	0.0007	N/A	33.1 kw	YES	YES	YES	N/A	NO	YES

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1																
2																
3																
4																
5																

Emergency Control Valve accessible:

YES

Gas Tightness Satisfactory:

YES

Signatures

Report Issued By:

Winston Eric Bridge

Gas ID Number:

4131890

Number Of Appliances Tested:

Equipotential Bonding:

YES

Report Received By:

[Signature]

Date:

Wed-11-10-2017

NEXT INSPECTION DUE ON

Installation Pass:

YES

Name:

Signed:

Date:

Wed-11-10-2017

CO Alarm fitted and working?

Smoke alarm fitted and working?

This Gas Safety Report was created by Gas Checker Software 2016 all rights reserved www.gaschecker.co.uk