



## Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.

Certificate Reference
35 Rothesay

Certificate No: 1

Engineers Details						Insta	ıllation [	Details					Client De	etails					
Trading Title		GW Plumbing and Heating					Installation Address						Client Address	: I	Houses				
Address		7 Hertford Close						35 Rothesay Avenue					7 100.000	90					
		Syston					Lenton						Paget	Street					
		Leicester						Nottingham					Loughborough						
		Post Code: LE7 2FA						Post Code: NG7 1PU					Post Code: LE11 5DT				DT		
Gas Safe No:		944162 Telephone No: 07788379040				Tel	Telephone No:					 Telephon							
Appliance Details					Inspection Details														
	Locatio	on	Appliance Type	Make	Model	Combustion LOW (CO2% or CO/CO2 ratio)	Combustion HIGH (CO2% or CO/CO2 ratio)	Heat Input (KW) or Operating Pressure	CO Reading (ppm)	Appliance Inspected (YES/NO/NA/VIO) (VD. = Vauel Impeden ONIV)	FlueType (OF/RS/FL)	Landlords Appliance (YES/NO/NA)	Safety Device(s) Correct Operation (YES/NO/NA)	Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)	
1	Kitche	en	Combi boiler	Main	Eco Combi 30	0.0001	0.0004	29.6 kw	31ppm	YES	RS	YES	YES	YES	YES	PASS	NO	YES	
2																			
3																			
4																			
5																			
Faults/Notes							Remedial Work Taken									Warnii	ng Notice	e Fixed	
1	1																		
2																			
3	;																		
4																			
5																			
Emergency Control Valve Accessible:  YES  Gas Tightness Satisfactory:  YES							Signatures Report Issued By: Gas ID Number:									555551	5555519		
Gas Installation Pipework Visual Inspection Satisfactory:														Date:	Fri-12-07-2024				
Nun	nber of Appli	ances Te	sted: 1	Equipotential I	Bonding: YES	Re	Report Received By:												
NEXT INSPECTION DUE ON OR BEFORE: Thu-31-07-2025 Installation Pass: YES						_	ıme: [	Signed:							Date:	Fri-12-0	7-2024		
СО	Alarm fitted 8	& working	g? YES Sr	moke alarm fitted &	& working? YES	]	Fo	or appliances	This Gas Sa	fety Report w	as created by	/ Gas Checker S d 'Appliance Safe	oftware all rights re e' response is bas	eserved ww ed on a visu	w.gaschecker.co. al check for obvio	.uk ous defects c	only.		