



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.

Certificate Reference

42 Teversal Avenue

Certificate No: 1

Engineers Details								Insta	Installation Details Client						Client D	etails					
Trading Title		GW Plumbing and Heating							Installation Address								Parr Houses				
Address		7 Hertford Close							aress	42 Teversal Avenue					Address	s 90	90				
		Syston							Lenton						Paget	t Street					
		Leicester								Nottingham					Loughborough						
		Post Code: LE7 2FA								Post Code: NG7 1PX							ı	Post Coc	le : LE11 5	DT	
Gas Safe No:		944162 Telephone No: 07788379040							Telephone No:					Telephone No:							
		<u> </u>							iepriorie iv	0.	Inspection Details				releption						
Appliance Details						T > 8	T 8		Inspec	tion Deta	ails		П Т		1						
	Locatio	Location		Appliance Type		e	Model	Combustion LOW (CO2% or CO/CO2 ratio)	Combustion HIGH (CO2% or CO/CO2 ratio)	Heat Input (KW) or Operating Pressure	CO Reading (ppm)	Appliance Inspected (YES/NO/NA/VIO) (ND = Veual Improdor Only)	FlueType (OF/RS/FL)	Landlords Appliance (YES/NO/NA)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)	
1	Bathro	Bathroom		Combi boiler		in	Eco Combi 30	0.0003	0.0010	29.4 kw	80PPM	YES	RS	YES	YES	NA	YES	PASS	NO	YES	
2																					
3																					
4																					
5																					
Faults/Notes							<u> </u>	Remedial Work Taken								Warning Notice Fixed					
1																					
2	2																				
3	3																				
4	4																				
5																					
Emergency Control Valve Accessible: YES Gas Tightness Satisfactory: YES									Signatures Report Issued By: Gas ID Number:									5555519			
Gas Installation Pipework Visual Inspection Satisfactory: YES									Name: Grant Wright Signed: Date:								Mon-22-07-2024				
Nun	Number of Appliances Tested: 1 Equipotential Bonding: YES									Report Received By:											
NEXT INSPECTION DUE ON OR BEFORE: Thu-24-07-2025 Installation Pass: YES							٦	ime:								Mon-22-07-2024					
СО	Alarm fitted 8	ı? T	noke alarn	n fitted 8	k working? YES]	This Gas Safety Report was created by Gas Checker Software all rights reserved www.gaschecker.co.uk														